

Submission Details

Submitter

Name	Irish Water Irish Water
Address	PO Box 6000, Dublin 1 Ireland.
Note	Submission made for incorrect Part 8. This submission refers to Moyross Ave upgrade Part 8.

In relation to application

Application Number	PT8LL95
Applicant Name	Limerick City and County Council
Development Address	Creval Park Moyross

Submission Details

Submitter

Name	Irish Water Irish Water
Address	PO Box 6000, Dublin 1 Ireland.
Note	

In relation to application

Application Number	PT8LL95
Applicant Name	Limerick City and County Council
Development Address	Creval Park Moyross

RECEIVED: 15/03/2024

**Irish Water's Statutory
Response to**

Limerick City & County Planning Authority



Uisce Éireann
Bosca OP 6000
Baile Átha Cliath 1
Éire

Irish Water
PO Box 6000
Dublin 1
Ireland

T: +353 1 89 25000
F: +353 1 89 25001
www.water.ie

RECEIVED: 15/03/2024

Planning Application No.

93

Date Lodged with Planning Authority:

21/02/2024

Development:

The proposed development the subject to this Part 8 will consist of the upgrade of c.200m of Moyross Avenue between the Sarsfield Gardens junction and the western boundary of the Corpus Christí Primary School, including: • A realignment of Moyross Avenue through the Corpus Christí Parish Church and Corpus Christí Primary School lands; • A reduction in the carriageway width to 6m together with raised speed table at the proposed new entrance to the Corpus Christí Primary school; • The provision of parallel set down car-parking spaces on both sides of Moyross Avenue; • Construction of 1.8m wide cycle tracks and 2m wide footpaths on both sides of Moyross Avenue; • The provision of replacement car-parking spaces to the rear of the Corpus Christí Parish Church; • Associated landscaping and siteworks.

Location :

Moyross Avenue, Ballynanty More, Limerick

IW Recommendation:

No Objection

IW Observations:

Comment: There is 200mm water main and three crossings running through the site as well as a 300mm foul sewer. Uisce Éireann has the following observations in respect of the proposed development: 1) Prior to the commencement of any construction works the applicant is to locate and protect all Uisce Éireann services and connections to same within the red-line site boundary. The applicant is to note that in accordance with the requirements of section 104 of the 2007 Water Services Act there shall be no building over water mains, common pipes, or sewers, and if found the applicant must contact Uisce Éireann with a proposal for altering at the cost of the applicant. 2) The integrity, operation and access to the sewer and watermain networks shall not be compromised by the proposed development works. 3) The proposed development works involved shall not adversely affect the operation of the sewer and watermain networks for the neighbouring properties. 4) Any works to either the watermain or sewer networks to be in accordance with Irish Water's Technical Documentation; 'Code of Practice's', 'Water Infrastructure Standard Details', and 'Wastewater Infrastructure Standard Details'.

RECEIVED: 15/03/2024

Signed on Behalf of Irish Water:

Maria O'Dwyer

Date:

Friday 15 March 2024

RECEIVED: 15/03/2024