

Submission Details

RECEIVED: 31/08/2023

Submitter

Name	Irish Water Irish Water
Address	PO Box 6000, Dublin 1 Ireland.
Note	

In relation to application

Application Number	PT8TT30
Applicant Name	Tipperary County Council
Development Address	Bouladuff & Clehile The Ragg, Thurles

Your Ref: **Proposed improvement works and active travel measures,
The Ragg, Thurles.**

Mr Marcus O'Connor,
Director of Services,
Tipperary County Council,
Civic Offices,
Limerick Road,
Nenagh,
Co. Tipperary

Date: 30th August, 2023

Uisce Éireann
Bosca OP 6000
Baile Átha Cliath 1
D01 WA07
Éire

Uisce Éireann
PO Box 6000
Dublin 1
D01 WA07
Ireland

T: +353 1 89 25000
F: +353 1 89 25001
www.water.ie

**RE: Uisce Éireann's observations RE: Part VIII - Proposed improvement works
and active travel measures, The Ragg, Thurles, Co.Tipperary**

Dear Sir/Madam,

Please accept this submission in respect of the above-referenced planning application for proposed road re-alignment and upgrade works, otherwise known as the proposed improvement works and active travel measures in The Ragg, Thurles, Co.Tipperary

Uisce Éireann (UÉ) has reviewed the plans and particulars submitted with the application and have the following observations;

Uisce Éireann has no objection in principle to the proposal, however our records indicate the presence of water services infrastructure which may be impacted by the proposed development.

Therefore, Uisce Éireann requests the applicant to liaise with Uisce Éireann during the final design stage of the proposed development works in order to ascertain the impact on the existing Uisce Éireann network infrastructure so that protection works or replacement works can be agreed and carried out as appropriate.

Uisce Éireann requests that prior to any works being undertaken, that the location of any / all watermain(s) / sewer(s) and any associated fittings shall be confirmed on the ground with the local water curator.

The new kerb-lines should be set out on site so that the local water curator can ensure that the new kerb-line will not be sitting on top of the existing water main as the new kerb-line has the potential to be close to this infrastructure.

Uisce Éireann requests that the integrity of the infrastructure shall be protected during the works and the Council's water service's engineer consulted prior to and during construction.

Uisce Éireann respectfully requests any grant of permission be conditioned as follows:

1. The applicant shall liaise with Uisce Éireann regarding existing water services infrastructure in the vicinity of the proposal prior to and during construction to ensure that the integrity of Uisce Éireann's infrastructure shall be protected both during and after the completion of the works relating to this proposal.
2. Any proposals by the applicant to divert or build over existing water or wastewater services shall be submitted to Uisce Éireann for written approval prior to works commencing.
3. Separation distances between the existing Uisce Éireann assets and proposed structures, other services, trees, etc. have to be in accordance with the Uisce Éireann Codes of Practice and Standard Details.
4. All development shall be carried out in compliance with Uisce Éireann Standards codes and practices.
5. All Uisce Éireann infrastructure affected by the works shall be reinstated in accordance with Uisce Éireann Standards.

Reason: To ensure adequate provision of water and wastewater facilities.

Queries relating to the terms and observations above should be directed to planning@water.ie

PP. Ali Robinson

Yvonne Harris

Connections and Developer Services